



FOOD, PHARMACEUTICAL, MANUFACTURING & INSTRUMENT AIR

PROCESS AIR					
TRI Item No.	B1	BLI *	A82	C23	BLD *
Typical Use/Application	Pharmaceutical/ Food/ Manufacturing: Indirect Product Contact	Pharmaceutical/ Food/ Manufacturing: Indirect Product Contact No Specification Comparison	Pharmaceutical/ Food/ Manufacturing: Direct Product Contact (with Dessiccant Dryer)	Pharmaceutical/ Food/ Manufacturing: Direct Product Contact (with Refrigerated Dryer)	Pharmaceutical/ Food/ Manufacturing: Direct Product Contact No Specification Comparison
Total hydrocarbon content (as methane) ppm	5		2	2	
Oil (condensed) (mg/m3 at NTP)	1		0.1	0.1	
Halogenated Solvents (ppm)	5	Same test as B1 No Spec Comparison Dessiccant Dryer System	5	5	Same test as A82 (dessiccant dryer) or C23 (refrigerated dryer) No Spec Comparison
Water (ppm)	1267		67	1267	
Dewpoint °F	0		- 50	0	
Baseline Reporting Available	YES		YES	YES	

NOTES: * Baseline results are given to determine air system quality/capabilities; no specification comparison is reported.

TRI suggests performing a baseline no specification comparison, testing on new or untested systems to help determine the appropriate specification requirements.

(Use TRI Item no. BLI for indirect product contact or BLD for direct product contact air tests)